

Blowdown Heat Recovery Process - Temperature Evaluation
One Minute Time Stamp Intervals from Externally Mounted Thermocouples
Two x CB 300 HP Boilers Manual and Conductivity Controlled Blowdown
August 1st to August 31th, 2009

	Flash Steam Temp. (Deg. F)		Make-up Water Temp. (Deg. F)		Delta T Make-up Temp. (Deg. F)	
Minimum	134.8		79.2		7.2	
Maximum	268.9		157.8		85.8	
Average	170.1		94.3		22.3	
Standard Deviation	20.2		9.2		9.2	
Data Range Count	130	175	75	100	0	20
Minutes	28,227		32,751		19,414	
% of Time	73.9%		85.8%		50.9%	
	176	200	101	125	21	40
	5,483		4,074		13,541	
Total Minutes	14.4%		10.7%		35.5%	
Reported	201	225	126	150	41	60
	2,983		705		1,609	
38,171	7.8%		1.8%		4.2%	
	226	250	151	175	61	81
	487		3		359	
	1.3%		0.01%		0.9%	
	251	275				
	72					
	0.2%					

Notes: To calculate the percent of time any of the data sets are within a fixed temperature range, the number of data points counted between the low and high number are divided into the total number of minutes (data points collected) for each set.

On the following Graphics page, the Red lines represent the Flash Steam Outlet Temperature, the Blue line represents the Make-up Out Temperature and the Yellow line represents the average inlet water temperature during the period reported.

Blowdown Heat Recovery Process - Temperature Evaluation
One Minute Time Stamp Intervals from Externally Mounted Thermocouples
2 x CB-300HP Boilers / Manual and Conductivity Controlled Blowdown

